



SP-Analytica, Inc. - Juneau  
 5438 Shaune Drive  
 Juneau, AK 99801  
 Phone: 907-780-6668  
 Fax: 907-780-6670

City of Wrangell  
 Attn: Wayne McHolland  
 P.O. Box 531  
 Wrangell, AK 99929  
 907-874-4212  
 Fax: 907 874-3952 or 874-4207

Report Date: 11/16/2010  
 Receipt Date: 11/1/2010  
 Sample Date: 10/29/2010  
 Sample Time: 9:40:00AM  
 Collected By: unk

Client Sample ID: Lower Res. Tap  
 Sampling Location: Lower Res. Tap  
 Client Project: WRANGELL  
 Sample Matrix: Aqueous  
 COC #: 56156  
 PWS#:  
 Residual Chlorine:  
 Comments:

Flag Definitions:

MRL = Method Reporting Limit  
 MCL = Maximum Contaminant Limit  
 B = Present also in Method Blank  
 H = Exceeds Regulatory Limit  
 M = Matrix Interference  
 J = Estimated Value  
 D = Lost to Dilution  
 \*\* = RL higher than MCL; target not detected  
 TNC = Too Numerous to Count - result rejected  
 CF = Confluent Growth - result rejected  
 TCNG = Turbid Culture No Growth - rejected

Lab#: J1011004-02A

Analysis Method					Prep	Prep	Analysis		
Parameter	Result	Units	Flags	MRL	MCL	Method	Date	Date	Analyst
200.7/200.7 (Aqueous) - Total/TR					<i>Test was conducted by: Analytica - Thornton</i>				
Iron	0.450	mg/L	H	0.050	0.3	200.2	11/4/2010	11/4/2010	SM

*only Iron  
 Test mg  
 of c  
 can award*